



We Ace It

Struct Ace Engineers

Shop No. 15, TNSCB (J.J) Complex,
Anna Nagar, Thirumangalam, Chennai - 600 040.
PH : 044 2615 1221 | Mobile : +91 96771 18362
Email : Structaceengineers@gmail.com

FORM-B

STATEMENT ACCOMPANYING THE CERTIFICATE OF STRUCTURAL SOUNDNESS

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (B) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDING (LICENSING) ACT 1965 (TAMIL NADU ACT 13 OF 1965 REFERRED TO RULE 4 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) RULES 1966.

I have inspected the building mentioned below and it is to be used as a public building for the purpose mentioned in the statement. A license may be granted for the period of three years from 11.06.2025 to 10.06.2028.

Located at S.No 36/1,2,3A,37/3A&4 of Mambakkam village, Uthiramerur Taluk, Kanchipuram district.

Plinth area G.F 2040sq.m

This certificate covers the main building only and does not include any other structures such as sunshade, portico and compound wall. I do hereby advice that the periodical maintenance is to be carried out as per civil engineering code of practice.

This certificate does not include any thatched sheds and also any flammable building material utility. If any thatched sheds found after the issue of this certificate this certificate gets invalid. Also, it is found that there are no visible cracks or defects in the building and it is structurally sound. This certificate does not include any eventuality caused due to natural calamity.



P.J. PRABAHARAN, B.E, FIV

Valuer; Regd. Engineer CMDA & GCC

RE/GR-I/19/05/176; RE10 210 2019

PWD APPROVED PANEL ENGINEER

#15, TNSCB (JJ) Complex, Anna Nagar, Chennai-40, Cell: 6381361568; 044-26151



We Ace It

Struct Ace Engineers

Shop No. 15, TNSCB (J.J) Complex,
Anna Nagar, Thirumangalam, Chennai - 600 340.
PH : 044 2615 1221 | Mobile : +91 98771 18362
Email : Structaceengineers@gmail.com

FORM-C

STATEMENT ACCOMPANYING THE CERTIFICATE OF STRUCTURAL SOUNDNESS

I certify that I have inspected the building mentioned in the statement listed below the detailed technical features.

1. FOUNDATION

- | | |
|-----------------------------|-----------------|
| a. Depth below ground level | 1.83m |
| b. Nature of soil | brownish clayey |
| c. Pressure at foundation | 80 KN/sq.m |
| d. Safe bearing capacity | 120KN/sq.m |

2. SUPERSTRUCTURE

- a. RCC columns ,beams and slabs
- b. Brick work in C.M 1:5

The structure of the building verified by me with relevant ISIS loading standards 875 (latest version) and other Indian standard of civil engineering code of practices and declare that the building is structurally sound and it can be used as a public building for the purpose mentioned above.



P.J. PRABAHARAN, B.E, FIV
Valuer; Regd. Engineer CMDA & GCC
RE/GR-I/19/05/176; RE10 210 2019
PWD APPROVED PANEL ENGINEER
#15, TNSCB (JJ) Complex, Anna Nagar West,
Chennai-40, Cell: 6381361568- 044-26151221



We Ace It

Struct Ace Engineers

Shop No. 15, TNSCB (J.J) Complex,
Anna Nagar, Thirumangalam, Chennai - 600 040.
PH : 044 2615 1221 | Mobile : +91 96771 18362
Email : Structaceengineers@gmail.com

STATEMENT ACCOMPANYING THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the building	Age	Value	No of storey	Short description
S.No 36/1,2,3A,37/3A&4 of Mambakkam village,Uthiramerur Taluk, Kanchipuram district.	New	Rs 4.0 lCr	G	

Purpose for which the building is to be certified	Period	No of persons to accommodate	Remark
School	3 years 11.06.2025 to 10.06.2028	500 pupils	Building is structurally sound




P.J. PRABAHARAN, B.E, FIV
Valuer; Regd. Engineer CMDA & GCC
RE/GR-I/19/05/176; RE10 210 2019
PWD APPROVED PANEL ENGINEER
#15, TNSCB (JJ) Complex, Anna Nagar West,
Chennai-40, Cell: 6381361568; 044-26151221



We Ace It

Struct Ace Engineers

Shop No. 15, TNSCB (J.J) Complex,
Anna Nagar, Thirumangalam, Chennai - 600 040.
PH : 044 2615 1221 | Mobile : +91 96771 18362
Email : Structaceengineers@gmail.com

FORM - E

**FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB-SECTION
(4) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDING (LICENSING) ACT
1965 (TAMIL NADU 1 OF 1965) REFERRED TO IN RULE 4 OF THE TAMIL NADU
PUBLIC (LICENSING) RULES 1966-**

1.	Name and designation of inspecting authority or officer appointed or having jurisdiction under any other act or Law	Er. P. J. Prabakaran B.E., F.I.V., Licensed surveyor & Valuer Panel engineer approved by district collector Approved by board of engineers, PWD, TN
2.	Location of the building inspected No: Name of the place Municipal Corporation / Municipality Panchayat/Panchayat Union/Township cantonment	S.No 36/1,2,3A,37/3A&4 of Mambakkam village, Uthiramerur Taluk, Kanchipuram district.
3.	Date of Inspection	10.06.2025
4.	Purpose for which the building is used	For running school
5.	Nature of defects noticed	Nil
6.	Suggestion of rectifying defects	NA
7.	If in dangerous condition immediate action recommended to be taken	NA



P.J. PRABAHARAN, B.E, FIV
Valuer: Regd. Engineer CMDA & GCC
RE/GR-I/19/05/176; RE10 210 2019
PWD APPROVED PANEL ENGINEER
#15, TNSCB (Jj) Complex, Anna Nagar West,
Chennai-40, Cell: 6381361568; 044-2615122